

# LICENCE

No. 21100 replaces No.19504

Issued to:

Applicant:

**Monplast Srl. Unipersonale**

**S.R 11 N°44**

**36053 GAMBELLARA (VI)**

**Italy**

Licensee:

**Monplast Srl. Unipersonale**

**S.R 11 N°44**

**36053 GAMBELLARA (VI)**

**Italy**



Product : conduit systems for cable management

Trade name(s) : MONPLAST

Type(s)/model(s) : ICTA- MS

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1429

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 16/01/2019

Ir. C. Lana,  
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



**SPECIFICATION OF THE CERTIFIED PRODUCT**

**Product data**

Product : conduit systems for cable management  
 Trade name(s) : MONPLAST  
 Type(s)/Model(s) : ICTA- MS  
 material : insulating  
 nominal size(s) (outside diameters) : 16, 20, 25, 32 mm  
 classification : 3422  
 degree of protection : IP 40

**Additional information**

See Appendix

**TESTS**

**Test requirements**

NBN EN 60423 based on EN 60423:2007  
 NBN EN 61386-1 based on EN 61386-1:2008  
 NBN EN 61386-22 based on EN 61386-22:2004 + A11:2010

**Test results**

The test results are laid down in certification file ref.629966/01

**Remarks**


This certificate is based on IMQ certificate ref. CA02.03708 and test report ref. MI16-0009857-01

**Conclusion**

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 16/01/2019

Certification Manager :

A handwritten signature in blue ink, followed by the date '2019-01-16'.

**FACTORY LOCATION(S)**

MONPLAST Srl. Unipersonale  
Strada Regionale 11 44  
36053 Gambellara (Vicenza)  
Italy

Additional information:

Classification coding for conduits:

First digit : 3 Medium compression strength : 750 N

Second digit : 4 Heavy impact strength : 2 kg / 100 mm

Third digit : 2 Min. permanent application and installation temperature : -5°C

Fourth digit : 2 Max. permanent application and installation temperature : +90°C

Fifth digit : 3 Resistance to bending pliable/self recovering

Sixth digit : 2 Electrical properties with electrical insulating characteristics

Seventh digit: 4 Resistance to ingress of solid objects

Eighth digit : 0 Resistance to ingress of water

Ninth digit : - corrosion resistance

Tenth digit : 0 Tensile strength

Eleventh digit : 1 Resistance to flame propagation: non flame propagation: non declared or not applicable

Twelfth digit : 0 Suspended load capacity: non declared

Conduit type and colors:

ICTA 16, 20, 25 : Grey, Green

ICTA 32 : Grey

Sleeve types and color:

MS 16, 20, 25 and 32 : Transparent Grey

Halogen gas acid content test according to the standards EN 60754-1:2014 and ISO 10304-1:2017  
Measurement of pH and Conductivity according to standard EN 60754-2:2014